

					HP 3kW, gen. K			HP 5kW, gen. K			HP 7kW, gen. K			HP 9kW, gen. K			HP 5kW, gen. L			HP 7kW, gen. L			HP 9kW, gen. L			
Moc przy		T= -20°C				2.5 kW	2.2 kW	2.1 kW	4.1 kW	3.8 kW	3.4 kW	4.5 kW	4.2 kW	3.9 kW	5.0 kW	4.6 kW	4.0 kW	4.7 kW	3.8 kW	3.6 kW	5.5 kW	5.1 kW	4.9 kW	7.0 kW	6.2 kW	5.6 kW
Moc grzałki		const.				3.0 kW	3.0 kW		3.0 kW			3.0 kW			3.0 kW			3.0 kW			3.0 kW			3.0 kW		
Moc max		T= -20°C				5.5 kW	5.2 kW	5.1 kW	7.1 kW	6.8 kW	6.4 kW	7.5 kW	7.2 kW	6.9 kW	8.0 kW	7.6 kW	7.0 kW	7.7 kW	6.8 kW	6.6 kW	8.5 kW	8.1 kW	7.9 kW	10.0 kW	9.2 kW	8.6 kW
Strefa klimatyczna					W 35 W 45 W 55			W 35 W 45 W 55			W 35 W 45 W 55			W 35 W 45 W 55			W 35 W 45 W 55			W 35 W 45 W 55			W 35 W 45 W 55			
I	II	III	IV	V	ΔSK			ΔSK			ΔSK			ΔSK			ΔSK			ΔSK			ΔSK			
-16	-18	(-20 °C)	-22	-24	R32, 1 faz.			R32, 1 faz.			R32, 1 faz.			R32, 1 faz.			R290, 1 faz.			R290, 1 faz.			R290, 1 faz.			
2.2	2.4	2.5 kW	2.6	2.8	Tbiv	-18 °C	-17 °C	-16 °C																		
					%max	220%	208%	204%	282%	270%	256%	298%	289%	276%	318%	303%	282%	308%	264%	264%	340%	316%	316%	400%	344%	
2.7	2.8	3.0 kW	3.2	3.3	Tbiv	-13 °C	-12 °C	-12 °C			-19 °C															
					%max	183%	173%	170%	235%	225%	213%	248%	241%	230%	265%	253%	235%	257%	220%	220%	283%	263%	263%	333%	287%	
3.1	3.3	3.5 kW	3.7	3.9	Tbiv	-10 °C	-9 °C	-9 °C			-18 °C			-20 °C												
					%max	157%	149%	146%	201%	193%	183%	213%	207%	197%	227%	217%	201%	220%	194%	189%	243%	231%	226%	286%	263%	
3.5	3.8	4.0 kW	4.2	4.5	Tbiv	-7 °C	-6 °C	-5 °C	-18 °C	-17 °C	-15 °C	-19 °C	-18 °C	-18 °C			-18 °C	-19 °C	-19 °C	-19 °C			-19 °C			
					%max	138%	130%	128%	176%	169%	160%	186%	181%	173%	199%	190%	176%	193%	170%	165%	213%	203%	198%	250%	230%	
4.0	4.2	4.5 kW	4.8	5.0	Tbiv	-4 °C	-4 °C	-4 °C	-17 °C	-16 °C	-14 °C	-18 °C	-17 °C	-16 °C	-19 °C	-20 °C	-17 °C	-17 °C	-17 °C	-17 °C			-19 °C	-18 °C		
					%max	122%	116%	113%	157%	150%	142%	166%	161%	153%	177%	168%	156%	171%	151%	147%	189%	180%	176%	222%	204%	
4.4	4.7	5.0 kW	5.3	5.6	Tbiv	-1 °C	-1 °C	-1 °C	-15 °C	-14 °C	-13 °C	-17 °C	-16 °C	-15 °C	-19 °C	-19 °C	-16 °C	-15 °C	-15 °C	-16 °C	-19 °C	-17 °C	-16 °C		-19 °C	
					%max	110%	104%	102%	141%	135%	128%	149%	145%	138%	159%	152%	141%	154%	136%	132%	170%	162%	158%	200%	184%	
4.9	5.2	5.5 kW	5.8	6.1	Tbiv	1 °C	1 °C	1 °C	-13 °C	-13 °C	-11 °C	-15 °C	-15 °C	-13 °C	-18 °C	-18 °C	-15 °C	-13 °C	-13 °C	-13 °C	-18 °C	-16 °C	-14 °C		-19 °C	
					%max	100%	95%	93%	128%	123%	116%	135%	131%	125%	145%	138%	128%	140%	124%	120%	155%	147%	144%	182%	167%	
5.3	5.7	6.0 kW	6.3	6.7	Tbiv	3 °C	3 °C	3 °C	-11 °C	-11 °C	-10 °C	-14 °C	-13 °C	-12 °C	-17 °C	-17 °C	-14 °C	-11 °C	-11 °C	-11 °C	-16 °C	-14 °C	-13 °C		-18 °C	
					%max	92%	87%	85%	118%	113%	107%	124%	121%	115%	133%	126%	117%	128%	113%	110%	142%	135%	132%	167%	153%	
5.8	6.1	6.5 kW	6.9	7.2	Tbiv				-9 °C	-9 °C	-9 °C	-13 °C	-11 °C	-10 °C	-17 °C	-16 °C	-12 °C	-9 °C	-9 °C	-9 °C	-14 °C	-12 °C	-11 °C		-19 °C	
					%max	85%	80%	78%	108%	104%	98%	115%	111%	106%	122%	117%	108%	118%	105%	102%	131%	125%	122%	154%	142%	
6.2	6.6	7.0 kW	7.4	7.8	Tbiv				-8 °C	-8 °C	-7 °C	-11 °C	-10 °C	-9 °C	-16 °C	-14 °C	-11 °C	-7 °C	-7 °C	-7 °C	-12 °C	-10 °C	-10 °C		-17 °C	
					%max	79%	74%	73%	101%	97%	91%	106%	103%	99%	114%	108%	101%	110%	97%	94%	121%	116%	113%	143%	131%	
6.6	7.1	7.5 kW	7.9	8.4	Tbiv				-6 °C	-6 °C	-6 °C	-10 °C	-8 °C	-7 °C	-15 °C	-12 °C	-10 °C	-6 °C	-6 °C	-6 °C	-10 °C	-9 °C	-9 °C		-16 °C	
					%max	73%	69%	68%	94%	90%	85%	99%	96%	92%	106%	101%	94%	103%	91%	88%	113%	108%	105%	133%	123%	
7.1	7.5	8.0 kW	8.5	8.9	Tbiv				-4 °C	-4 °C	-5 °C	-8 °C	-7 °C	-6 °C	-14 °C	-10 °C	-8 °C	-5 °C	-5 °C	-5 °C	-8 °C	-8 °C	-8 °C		-14 °C	
					%max	69%	65%	64%	88%	85%	80%	93%	90%	86%	99%	95%	88%	96%	85%	83%	106%	101%	99%	125%	115%	
7.5	8.0	8.5 kW	9.0	9.5	Tbiv				-3 °C	-3 °C	-3 °C	-6 °C	-6 °C	-5 °C	-13 °C	-8 °C	-7 °C	-3 °C	-3 °C	-3 °C	-7 °C	-7 °C	-7 °C		-13 °C	
					%max	65%	61%	60%	83%	80%	75%	88%	85%	81%	94%	89%	83%	91%	80%	78%	100%	95%	93%	118%	108%	
8.0	8.5	9.0 kW	9.5	10.0	Tbiv				-2 °C	-2 °C	-2 °C	-5 °C	-5 °C	-4 °C	-10 °C	-7 °C	-6 °C	-2 °C	-2 °C	-2 °C	-6 °C	-6 °C	-6 °C		-11 °C	
					%max	61%	58%	57%	78%	75%	71%	83%	80%	77%	88%	84%	78%	86%	76%	73%	94%	90%	88%	111%	102%	
8.4	9.0	9.5 kW	10.0	10.6	Tbiv				1 °C	1 °C	1 °C	-4 °C	-4 °C	-3 °C	-6 °C	-5 °C	-4 °C	-2 °C	-2 °C	-2 °C	-5 °C	-5 °C	-5 °C		-10 °C	
					%max	58%	55%	54%	74%	71%	67%	78%	76%	73%	84%	80%	74%	81%	72%	69%	89%	85%	83%	105%	97%	
8.9	9.4	10.0 kW	10.6	11.1	Tbiv				1 °C	1 °C	1 °C	-3 °C	-4 °C	-3 °C	-4 °C	-4 °C	-3 °C	1 °C	1 °C	1 °C	-4 °C	-4 °C	-4 °C		-8 °C	
					%max	55%	52%	51%	71%	68%	64%	75%	72%	69%	80%	76%	70%	77%	68%	66%	85%	81%	79%	100%	92%	
9.3	9.9	10.5 kW	11.1	11.7	Tbiv				1 °C	1 °C	1 °C	-2 °C	-3 °C	-2 °C	-3 °C	-3 °C	-2 °C	1 °C	1 °C	1 °C	-3 °C	-3 °C	-3 °C		-7 °C	
					%max	52%	50%	49%	67%	64%	61%	71%	69%	66%	76%	72%	67%	73%	65%	63%	81%	77%	75%	95%	88%	
9.7	10.4	11.0 kW	11.6	12.3	Tbiv				1 °C	1 °C	1 °C	1 °C	-2 °C	1 °C	-2 °C	-2 °C	-2 °C	1 °C	1 °C	1 °C	-3 °C	-3 °C	-2 °C		-6 °C	
					%max	50%	47%	46%	64%	61%	58%	68%	66%	63%	72%	69%	64%	70%	62%	60%	77%	74%	72%	91%	84%	
10.2	10.8	11.5 kW	12.2	12.8	Tbiv				0 °C	0 °C	0 °C	0 °C	0 °C	0 °C	-2 °C	-1 °C	0 °C				1 °C	0 °C	0 °C		-4 °C	
					%max	48%	45%	44%	61%	59%	56%	65%	63%	60%	69%	66%	61%	67%	59%	57%	74%	70%	69%	87%	80%	