1-13. Product Fiche

U-100PZH3E5

ENERG Y IJA IE IA
енергия · ενεργεια

Panasonic

Model name		SEER						SCOP																
								Warmer					Average							Colder				
Indoor Unit	Outdoor Unit	A～G	kW	SEER	*2 kWh/annum	dB	dB	A～G	kW	SCOP	*2 kWh/annum	elbu (2℃) kW	A～G	kW	SCOP	*2 kWh/annum	dB	dB	elbu (-10℃) kW	A～G	kW	SCOP	*2 kWh/annum	elbu (-22℃) kW
S-1014PU3E S-1014PU3E(100)	U-100PZH3E5	A++	10.0	7.8	449	60	69	-	×	×	×	×	A++	8.0	4.9	2286	60	69	0.00	-	×	×	×	×
S-3650PU3E × 2 S-3650PU3E(50)	U-100PZH3E5	A++	10.0	7.8	449	47	69	-	×	×	×	×	A++	8.0	4.9	2283	47	69	0.00	-	×	×	×	×
S-3650PU3E × 3 S-3650PU3E(36)	U-100PZH3E5	A++	10.0	7.8	449	45	69	-	×	×	×	×	A++	8.0	4.9	2284	45	69	0.00	-	×	×	×	×
S-1014PF3E S-1014PF3E(100)	U-100PZH3E5	A++	9.5	7.4	447	56	69	-	×	×	×	×	A+	7.8	4.5	2424	56	69	0.00	-	×	×	×	×
S-3650PF3E × 2 S-3650PF3E(50)	U-100PZH3E5	A++	9.5	6.8	486	57	69	-	×	×	×	×	A+	7.8	4.2	2557	57	69	0.00	-	×	×	×	×
S-3650PF3E × 3 S-3650PF3E(36)	U-100PZH3E5	A++	9.5	6.6	500	53	69	-	×	×	×	×	A+	7.8	4.2	2556	53	69	0.00	-	×	×	×	×
S-6010PK3E S-6010PK3E(100)	U-100PZH3E5	A++	9.5	6.4	520	65	69	-	×	×	×	×	A+	8.0	4.1	2732	65	69	0.00	-	×	×	×	×
S-3650PK3E × 2 S-3650PK3E(50)	U-100PZH3E5	A++	10.0	6.4	547	56	69	-	×	×	×	×	A+	8.0	4.1	2730	56	69	0.00	-	×	×	×	×
S-3650PK3E × 3 S-3650PK3E(36)	U-100PZH3E5	A++	10.0	6.4	547	51	69	-	×	×	×	×	A+	8.0	4.1	2731	51	69	0.00	-	×	×	×	×
S-1014PT3E S-1014PT3E(100)	U-100PZH3E5	A++	9.5	7.3	456	60	69	-	×	×	×	×	A++	7.8	4.7	2323	60	69	0.00	-	×	×	×	×
S-3650PT3E × 2 S-3650PT3E(50)	U-100PZH3E5	A++	9.5	7.1	468	55	69	-	×	×	×	×	A++	7.8	4.7	2324	55	69	0.00	-	×	×	×	×
S-3650PT3E × 3 S-3650PT3E(36)	U-100PZH3E5	A++	9.5	6.6	499	54	69	-	×	×	×	×	A+	7.8	4.5	2400	54	69	0.00	-	×	×	×	×

ENERGIA · ЕНЕРГИЯ · ΕΝΕΡΓΕΙΑ · ENERGIJA · ENERGY · ENERGIE · ENERGI

626/2011

R32 （GWP=675）*1

*1
Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 675.
This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 675 times higher than 1 kg of CO2, over a period of 100 years.
Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

*2
Energy consumption "XYZ" kWh per year, based on standard test results.
Actual energy consumption will depend on how the appliance is used and where it is located.